

OHA Drinking Water Services

PWS ID: **93909** ---- MOLALLA RIVER ACADEMY

Lead & Copper Summary Results

Lead and Copper Compliance Actions

- No lead and copper schedules found.

Lead and copper results shown are the 90th percentile summary results. [See all detailed results.](#)

Consumer notice date is the date water customers were notified of their tap results. Consumer notice records are not available prior to 2016.

Action Levels: Lead = 0.015 mg/L; Copper = 1.3 mg/L. Action level exceedances are indicated with **bold red text**.

Sample Dates	Date Received	Sample Count	Duration	Lead (mg/L)	Copper (mg/L)	Consumer Notice Date
Aug 08, 2023 - Aug 08, 2023	Aug 25, 2023	5	3Y	0.0000	0.0000	
Jul 21, 2020 - Jul 21, 2020	Aug 05, 2020	5	3Y	0.0030	0.0280	
Aug 08, 2017 - Aug 08, 2017	Aug 31, 2017	5	3Y	0.0000	0.0000	
Sep 30, 2014 - Sep 30, 2014	Oct 13, 2014	5	3Y	0.0000	0.0000	
Sep 29, 2011 - Sep 29, 2011	Oct 21, 2011	5	3Y	0.0030	0.0510	
Jun 03, 2008 - Jun 03, 2008	Jul 29, 2008	5	3Y	0.0020	0.0600	
Aug 01, 2005 - Aug 01, 2005	Aug 08, 2005	5	3Y	0.0115	0.0750	
Jun 27, 2002 - Jun 27, 2002	Jul 15, 2002	5	3Y	0.0030	0.0950	
Jan 01, 2000 - Jun 27, 2000	Jul 11, 2000	5	YR	0.0020	0.0700	
Jan 01, 1999 - Jun 08, 1999	Jun 24, 1999	5	YR	0.0040	0.0600	
Jan 01, 1998 - Jun 09, 1998	Jun 22, 1998	5	YR	0.0070	0.1500	
Jan 01, 1997 - Jun 05, 1997	Jun 19, 1997	5	6M	0.0020	0.1800	
Jul 01, 1994 - Dec 02, 1994	Mar 27, 1995	5	6M	0.0030	0.1800	