



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/24/2025
Received: 09/17/2025
Sampled By: Ryan Powell
Work Order: 5260058

C
L
I
E
N
T
Molalla River Academy
Attn: Iva Quinlan
16897 S Callahan Rd
Molalla OR, 97038
Phone: (503) 829-6672

Project: ODE LEAD

Project # : -

Sample Type :

PWSID # : 4193909

Sampling Location: Molalla River Academy all Fixtures

Lab Number

		Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
5260058-01	Sample Name: 19250700- 001 CF Sampled: 9/15/25 7:00							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	1.34	ppb	1.00	15 ppb	09/19/25 22:46
5260058-03	Sample Name: 19250700- 003 BF Sampled: 9/15/25 7:05							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	1.51	ppb	1.00	15 ppb	09/19/25 22:49
5260058-04	Sample Name: 19250700- 004 BF Sampled: 9/15/25 7:05							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	09/19/25 22:53
5260058-05	Sample Name: 19250700- 005 BF Sampled: 9/15/25 7:05							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	09/19/25 22:57
5260058-06	Sample Name: 19250700- 006 BF Sampled: 9/15/25 7:10							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	09/19/25 23:01
5260058-07	Sample Name: 19250700- 007 CF Sampled: 9/15/25 7:10							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	5.34	ppb	1.00	15 ppb	09/19/25 23:05
5260058-08	Sample Name: 19250700- 008 SF Sampled: 9/15/25 7:10							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	2.07	ppb	1.00	15 ppb	09/19/25 23:09
5260058-09	Sample Name: 19250700- 009 SF Sampled: 9/15/25 7:10							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	9.76	ppb	1.00	15 ppb	09/19/25 23:13



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/24/2025
Received: 09/17/2025
Sampled By: Ryan Powell
Work Order: 5260058

C
L
I
E
N
T
Molalla River Academy
Attn: Iva Quinlan
16897 S Callahan Rd
Molalla OR, 97038
Phone: (503) 829-6672

Project: ODE LEAD

Project # : -

Sample Type :

PWSID # : 4193909

Sampling Location: Molalla River Academy all Fixtures

Lab Number

		Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
5260058-10	Sample Name: 19250702- 010 CF Sampled: 9/15/25 7:15							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	18.9	ppb	1.00	15 ppb	09/19/25 23:17 MCLE
5260058-11	Sample Name: 19250702- 011 DW Sampled: 9/15/25 7:15							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	2.69	ppb	1.00	15 ppb	09/19/25 23:21
5260058-12	Sample Name: 19250702- 012 CF Sampled: 9/15/25 7:15							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	09/19/25 23:45
5260058-13	Sample Name: 19250702- 013 DW Sampled: 9/15/25 7:15							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	3.03	ppb	1.00	15 ppb	09/19/25 23:49
5260058-14	Sample Name: 19250702- 014 CF Sampled: 9/15/25 7:15							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	11.9	ppb	1.00	15 ppb	09/19/25 23:53
5260058-15	Sample Name: 19250702- 015 DW Sampled: 9/15/25 7:15							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	1.42	ppb	1.00	15 ppb	09/19/25 23:57
5260058-16	Sample Name: 19250702- 016 BF Sampled: 9/15/25 7:15							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	1.28	ppb	1.00	15 ppb	09/20/25 00:01
5260058-17	Sample Name: 19250702- 017 BF Sampled: 9/15/25 7:15							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	1.34	ppb	1.00	15 ppb	09/20/25 00:05



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/24/2025
Received: 09/17/2025
Sampled By: Ryan Powell
Work Order: 5260058

C
L
I
E
N
T
Molalla River Academy
Attn: Iva Quinlan
16897 S Callahan Rd
Molalla OR, 97038
Phone: (503) 829-6672

Project: ODE LEAD

Project # : -

Sample Type :

PWSID # : 4193909

Sampling Location: Molalla River Academy all Fixtures

Lab Number

		Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
5260058-18	Sample Name: 19250702- 018 CF Sampled: 9/15/25 7:15							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	09/20/25 00:09
5260058-20	Sample Name: 19250702- 020 KF Sampled: 9/15/25 7:15							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	7.35	ppb	1.00	15 ppb	09/20/25 00:13
5260058-21	Sample Name: 19250702- 021 KF Sampled: 9/15/25 7:20							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	5.33	ppb	1.00	15 ppb	09/20/25 00:17
5260058-22	Sample Name: 19250702- 022 KF Sampled: 9/15/25 7:20							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	17.6	ppb	1.00	15 ppb	09/20/25 00:21 MCLE
5260058-23	Sample Name: 19250702- 023 KF Sampled: 9/15/25 7:20							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	1.05	ppb	1.00	15 ppb	09/20/25 00:45
5260058-24	Sample Name: 19250702- 024 WB Sampled: 9/15/25 7:20							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	09/20/25 00:49
5260058-25	Sample Name: 19250703- 025 BF Sampled: 9/15/25 7:20							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	09/20/25 00:53
5260058-26	Sample Name: 19250703- 026 BF Sampled: 9/15/25 7:20							Matrix: Drinking Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	09/20/25 00:57

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/24/2025
Received: 09/17/2025
Sampled By: Ryan Powell
Work Order: 5260058

C
L
I
E
N
T
Molalla River Academy
Attn: Iva Quinlan
16897 S Callahan Rd
Molalla OR, 97038
Phone: (503) 829-6672

Project: ODE LEAD
Project # : -
Sample Type :

PWSID # : 4193909
Sampling Location: Molalla River Academy all Fixtures

Lab Number

A All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director